



DLMS User Association

Pre-de-la-Fontaine 19 Tel. +41 22 980 980 0
CH-1217 Meyrin-Geneva Fax +41 22 980 980 9
Switzerland dlms@dlms.com

Certification

This is to certify that the metering equipment identified as:

Landis+Gyr Dialog ZMG300x/ZMG400x.P03

manufactured by:

Landis+Gyr

has successfully passed the DLMS/COSEM Conformance test.

The meter supports both Short name and Logical name referencing.

The test has been performed using Logical name referencing, via the RS 232 port.

The version of the COSEM object definitions .dat file is OBIS list v2.3_GK051026.dat.

The test has been performed by:

Landis+Gyr

on the date of:

31st October 2006

The digital signature of the test report is: 6298F4BB576ADBB9D8E9909025673945

The authenticity of the test report has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark - shown below - on its product duly identified and on its product literature.



A copy of the test report is filed by the DLMS UA. Copies are available from the manufacturer.

Geneva, the 2 November 2006

Paul Fuchs

Paul Fuchs
General Secretary