

## Certification No. 2076

This is to certify that the metering equipment identified as:

**Type: DTSD545-WC100      Active firmware Id=HMS3XX25121G6G00000000181219110**  
**Mgmt. SAP = 1 is "484C59303030303030303030303030" (HLY0000000000000)**  
**Manufactured by: Holley Technology LTD**

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 3.1 extended edition, 64bits, release 107
- Licensed to: 20180824\_Holley\_Technology\_China (2018/8/24)
- COSEM object definitions file version: Object\_defs\_v3.2\_released\_180306.dat
- Media identifier(s): Abstract, Electricity

Tests	Comm. profile & opening mode	Application contexts	Security features	Date and time	Test Result hash value
Test 1	HDLC, MODE_E	LONG_NAMES	–	19-FEB-2019 10:27:25	EC7EBE842C0DC773F7DD9ABAC7BE87D 3E6CE288518C6F4C2AF8231F76D89C4BD
Test 2	HDLC, DIRECT_HDLC	LONG_NAMES	–	25-FEB-2019 12:11:51	6B403B4F5C386E54400B04007CC976D04E 36583B7999AF96AE11E567D0552D08

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: [www.dlms.com](http://www.dlms.com).

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested; see the Summary. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 26<sup>th</sup> February 2019



Győző Kmety  
President

# Certification No. 2076

## Summary of features tested for Test 1

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

\*\*\*\*\*  
\* Identification \*  
\*\*\*\*\*

```
Identification = {
  Manufacturer = "\Holley Technology LTD"
  FLAGid = "\HLY"
  Type = "\DTSD545-WC100"
  ConfigurationId = "0000000000000001"
  SerialNr = "000020190120"
  Comment = "\FOR GBCS COSEM TEST"
  Comment = "\NO"
}
```

\*\*\*\*\*  
\* Summary \*  
\*\*\*\*\*

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC		All (MODE_E)				
APPL	58	0	19	0	39	0
COSEM	552	0	1	72	479	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

Communication profile: HDLC

Application context names: LONG\_NAMES

Authentication mechanisms: NO\_SECURITY, LOW\_LEVEL\_SECURITY

ACSE and xDLMS features: GET, MULTIPLE\_REFERENCES  
SERVICE\_SPECIFIC\_BLOCK\_TRANSFER, SET

Security features: (not collected)

Data protection features: (not collected)

Logical device(s) found: SAP = 1 is "484C5930303030303030303030303030"  
(HLY00000000000000)

Active firmware(s): Id=HMS3XX25121G6G00000000181219110

COSEM classes tested: 1,3,4,7(1),8,11,15,18

COSEM classes found but not tested: (none)

# Certification No. 2076

## Summary of features tested for Test 2

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

\*\*\*\*\*  
\* Identification \*  
\*\*\*\*\*

```
Identification = {  
  Manufacturer = "\Holley Technology LTD"  
  FLAGid = "\HLY"  
  Type = "\DTSD545-WC100"  
  ConfigurationId = "0000000000000001"  
  SerialNr = "000020190120"  
  Comment = "\FOR GBCS COSEM TEST"  
  Comment = "\NO"  
}
```

\*\*\*\*\*  
\* Summary \*  
\*\*\*\*\*

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC	36	0	1	0	35	0
APPL	58	0	19	0	39	0
COSEM	552	0	1	72	479	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

Communication profile: HDLC

Application context names: LONG\_NAMES

Authentication mechanisms: NO\_SECURITY, LOW\_LEVEL\_SECURITY

ACSE and xDLMS features: GET, MULTIPLE\_REFERENCES  
SERVICE\_SPECIFIC\_BLOCK\_TRANSFER, SET

Security features: (not collected)

Data protection features: (not collected)

Logical device(s) found: SAP = 1 is "484C5930303030303030303030303030"  
(HLY00000000000000)

Active firmware(s): Id=HMS3XX25121G6G000000000181219110  
Id=HMS3XX25121G6G000000000181219110

COSEM classes tested: 1, 3, 4, 7(1), 8, 11, 15, 18

COSEM classes found but not tested: (none)