

Certification No. 2263

This is to certify that the metering equipment identified as:

Type: WSA310-P02 Active firmware(s): Id=WSA310-P02METER.0333.V1.0.1 S=89F3
Mgmt. SAP = 1 is "57534732303230373230333030303033" (WSG2020720300003)
Manufactured by: Zhejiang WELLSUN Intelligent Technology Co.,Ltd.

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 3.1 standard edition, 64bits, release 107
- Licensed to: 20190912_ZWIT_Zhejiang (2019-09-12)
- COSEM object definitions file version: Object_defs_v3.3_released_180601.dat
- Media identifier(s): Abstract, Electricity

Tests	Comm. profile & opening mode	Application contexts	Security features	Date and time	Test Result hash value
Test 1	HDLC, DIRECT_HDLC	LONG_NAMES, LONG_NAMES_WITH_CIPHERING	GENERAL_GLO_CIPHERING SERVICE_SPECIFIC_GLO_CIPHERING, SUITE_0 SECURITY_ACTIVATE KEY_TRANSFER	13-JAN-2020 15:25:10	10A66D2AB2F97ABD12E45A80451EF7033AC4C24D062FB37E3CCB29628B409F89
Test 2	TCP			12-JAN-2020 21:01:50	A7DC4BA5B686CF7D0DFA6EBF9B8BDCA119FA74329C37E7DB4C7286AB36A30319
Test 3	HDLC, MODE_E			12-JAN-2020 18:15:45	BFD169C0D2BE9350D8D4DF0162E06F5B48001CCB98E260058846D2D97A8BB16F

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: www.dlms.com.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.




The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested; see the Summary. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.


Date: Zug, the 13th January 2020



Sergio Lazzarotto
Executive Director and President



Gyöző Kmethy
President Emeritus



Viktória Varjú Timárné
Certification Engineer

Certification No. 2263

Summary of features tested for Test 1

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****  
* Identification *  
*****
```

```
Identification = {  
  Manufacturer = "\Zhejiang WELLSUN Intelligent Technology Co.,Ltd."  
  FLAGid = "\WSG"  
  Type = "\WSA310-P02"  
  ConfigurationId = "\ConfigurationId"  
  SerialNr = "20300003"  
  Comment = "\comment 1"  
  Comment = "\comment N"  
}
```

```
*****  
* Summary *  
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC	36	0	4	0	32	0
APPL	75	0	20	0	55	0
COSEM	18777	0	14	169	18594	0
SYMSEC	39	0	9	0	30	0
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

Communication profile: HDLC

Application context names: LONG_NAMES, LONG_NAMES_WITH_CIPHERING

Authentication mechanisms: NO_SECURITY, LOW_LEVEL_SECURITY
HIGH_LEVEL_SECURITY_GMAC

ACSE and xDLMS features: ACTION, GET, MULTIPLE_REFERENCES, RLRQ_RLRE
SERVICE_SPECIFIC_BLOCK_TRANSFER, SET

Security features: GENERAL_GLO_CIPHERING
SERVICE_SPECIFIC_GLO_CIPHERING, SUITE_0
SECURITY_ACTIVATE, KEY_TRANSFER

Data protection features: (not collected)

Logical device(s) found: SAP = 1 is "57534732303230373230333030303033"
(WSG2020720300003)

Active firmware(s): Id=WSA310-P02METER.0333.V1.0.1 S=89F3

COSEM classes tested: 1, 3, 4, 5, 6, 7 (1), 8, 9, 11, 15 (1), 17, 18, 20, 21, 22
23 (1), 27 (1), 28 (2), 29 (2), 30, 40, 41, 42, 44, 45
64, 70, 71

COSEM classes found but not tested: (none)

Certification No. 2263

Summary of features tested for Test 2

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

* Identification *

```
Identification = {
  Manufacturer = "\Zhejiang WELLSUN Intelligent Technology Co.,Ltd."
  FLAGid = "\WSG"
  Type = "\WSA310-P02"
  ConfigurationId = "\ConfigurationId"
  SerialNr = "20300003"
  Comment = "\comment 1"
  Comment = "\comment N"
}
```

* Summary *

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC		All (Communication profile not HDLC)				
APPL	75	0	19	0	56	0
COSEM	18777	0	14	169	18594	0
SYMSEC	39	0	9	0	30	0
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

Communication profile: TCP

Application context names: LONG_NAMES, LONG_NAMES_WITH_CIPHERING

Authentication mechanisms: NO_SECURITY, LOW_LEVEL_SECURITY
HIGH_LEVEL_SECURITY_GMAC

ACSE and xDLMS features: ACTION, GET, MULTIPLE_REFERENCES, RLRQ_RLRE
SERVICE_SPECIFIC_BLOCK_TRANSFER, SET

Security features: GENERAL_GLO_CIPHERING
SERVICE_SPECIFIC_GLO_CIPHERING, SUITE_0
SECURITY_ACTIVATE, KEY_TRANSFER

Data protection features: (not collected)

Logical device(s) found: SAP = 1 is "57534700003230373230333030303033" (WSG)

Active firmware(s): Id=WSA310-P02METER.0333.V1.0.1 S=89F3

COSEM classes tested: 1, 3, 4, 5, 6, 7 (1), 8, 9, 11, 15 (1), 17, 18, 20, 21, 22
23 (1), 27 (1), 28 (2), 29 (2), 30, 40, 41, 42, 44, 45
64, 70, 71

COSEM classes found but not tested: (none)

Certification No. 2263

Summary of features tested for Test 3

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****
* Identification *
*****
```

```
Identification = {
  Manufacturer = "\Zhejiang WELLSUN Intelligent Technology Co.,Ltd."
  FLAGid = "\WSG"
  Type = "\WSA310-P02"
  ConfigurationId = "\ConfigurationId"
  SerialNr = "20300003"
  Comment = "\comment 1"
  Comment = "\comment N"
}
```

```
*****
* Summary *
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC		All (MODE_E)				
APPL	75	0	20	0	55	0
COSEM	18777	0	14	169	18594	0
SYMSEC	39	0	9	0	30	0
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

Communication profile: HDLC

Application context names: LONG_NAMES, LONG_NAMES_WITH_CIPHERING

Authentication mechanisms: NO_SECURITY, LOW_LEVEL_SECURITY
HIGH_LEVEL_SECURITY_GMAC

ACSE and xDLMS features: ACTION, GET, MULTIPLE_REFERENCES, RLRQ_RLRE
SERVICE_SPECIFIC_BLOCK_TRANSFER, SET

Security features: GENERAL_GLO_CIPHERING
SERVICE_SPECIFIC_GLO_CIPHERING, SUITE_0
SECURITY_ACTIVATE, KEY_TRANSFER

Data protection features: (not collected)

Logical device(s) found: SAP = 1 is "57534700003230373230333030303033" (WSG)

Active firmware(s): Id=WSA310-P02METER.0333.V1.0.1 S=89F3

COSEM classes tested: 1, 3, 4, 5, 6, 7 (1), 8, 9, 11, 15 (1), 17, 18, 20, 21, 22
23 (1), 27 (1), 28 (2), 29 (2), 30, 40, 41, 42, 44, 45
64, 70, 71

COSEM classes found but not tested: (none)