

Certification No. 2426

This is to certify that the metering equipment identified as:

Type: HXP100DIP_v2 Active firmware(s): Id=FP60054V02R036M001
Mgmt. SAP = 1 is "48584530303130373134303030303332" (HXE0010714000032)
Manufactured by: Hexing Electrical Co.,Ltd.

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 3.1 extended edition, 64bits, release 107
- Licensed to: 20160314_HEXING_Electrical_Co_Ltd_CHI (2016/3/14)
- COSEM object definitions file version: Object_defs_v3.3_released_180601.dat
- Media identifier(s): Abstract, Electricity

Tests	Comm. profile & opening mode	Application contexts	Security features	Date and time	Test Result hash value
Test 1	HDLC, DIRECT_HDLC	LONG_NAMES, LONG_NAMES_ WITH_ CIPHERING	SERVICE_SPECIFIC_ DED_CIPHERING SERVICE_SPECIFIC_ GLO_CIPHERING, SUITE_0	04-SEP-2020 13:31:05	4D8A65ECD34E0AB7E364ED7F92DB 6A5B10623FBD576FEDD9A59DED85 E18A2245

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: www.dlms.com.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.




The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested; see the Summary. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 7th September 2020



Sergio Lazzarotto
Executive Director and President



Győző Kmethy
President Emeritus



Viktória Varjú
Certification Engineer

Certification No. 2426

Summary of features tested for Test 1

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****
* Identification *
*****
```

```
Identification = {
  Manufacturer = "\Hexing Electrical Co.,Ltd."
  FLAGid = "\HXE"
  Type = "\HXP100DIP_v2"
  IUTIsModule = FALSE
  SerialNr = "\14000032"
  Comment = "\Client:Public,Meter Reader"
}
```

```
*****
* Summary *
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC	36	0	3	0	33	0
APPL	54	0	18	0	36	0
COSEM	611	0	4	27	580	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

```
Communication profile:          HDLC

Application context names:      LONG_NAMES, LONG_NAMES_WITH_CIPHERING

Authentication mechanisms:      NO_SECURITY, LOW_LEVEL_SECURITY

ACSE and xDLMS features:       GET, SELECTIVE_ACCESS
                                SERVICE_SPECIFIC_BLOCK_TRANSFER

Security features:              SERVICE_SPECIFIC_DED_CIPHERING
                                SERVICE_SPECIFIC_GLO_CIPHERING, SUITE_0

Data protection features:       (not collected)

Logical device(s) found:        SAP = 1 is "48584530303130373134303030303332"
(HXE0010714000032)

Active firmware(s):             Id=FP60054V02R036M001

COSEM classes tested:           1, 3, 4, 7(1), 8, 9, 15(1), 18, 20, 22, 23(1), 40, 41
                                45, 48, 64, 70, 71

COSEM classes found but not tested: (none)
```