

## Certification No. 1581

This is to certify that the metering equipment identified as:

**Type: DDZ1513 DIN III**

**Mgmt. SAP = 1, "49484D313030303731353939393930" (IHM1000715999990)**

manufactured by:

**SHENZHEN INHEMETER CO.,LTD.**

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT version 2.7
- Licensed to: 20120917\_Shenzhen\_Inhemeter\_Shenzhen\_China (2012-9-17)
- COSEM object definitions file version: Object\_defs\_v2.9\_released\_GKVV141201.dat
- Media identifiers used: [ABSTRACT, ELECTRICITY]

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	DIRECT_HDLC	LN	23 <sup>th</sup> Oct 2015	7620E4DADB8E4C76095747498B44E73A
Test 2	3-layer HDLC	MODE_E	LN	23 <sup>th</sup> Oct 2015	7C019C8E251BFBA48D9FB50F5A7DE7CC

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 26<sup>th</sup> October 2015



Paul Fuchs  
General Secretary