

Certification No. 1334

This is to certify that the metering equipment identified as:

Type: TLY2280

Mgmt. SAP = 1, "4C5945544C59323238304D3030303031" (LYETLY2280M00001)

manufactured by:

LINYANG

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT version 2.5
- Licensed to: LINYANG_Electronics_Qidong_China (2013-5-6)
- COSEM object definitions file version: Object_defs_v2.6_120912.dat
- Media identifiers used: [ABSTRACT, ELECTRICITY]

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	DIRECT_HDLC	LN	28 th May 2013	D16450F55B25972F5910144BCCAB9FA2
Test 2	TCP	-	LN	29 th May 2013	B170A6C21DF4830F568A7B891FFB4552

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 21st June 2013



Paul Fuchs
General Secretary