device
language
message
specification

DLMS User Association

Bahnhofstrasse 28
CH-6304 Zug
Switzerland

Tel. +36 28 514065
Fax +36 28 514066
dlms@dlms.com

Certification No. 1241

This is to certify that the metering equipment identified as:

Type: ST300FC
Mgmt. LDN: SAP = 1, "4D41433130313030303030303030323030" (MAC1010000000200)

manufactured by:

Meter&Control

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT version 2.5
- Licensed to: METER & CONTROL (2.4.2009)
- COSEM object definitions file version: Object_defs_v2.5_released_111107.dat
- Media identifiers used: [ABSTRACT, ELECTRICITY]

Test performed	Communication profile	Opening mode	Appl. context	Date and time	Digital signature of the test report
Test 1 RS485	3-layer HDLC	DIRECT_HDLC	LN	9th May 2012	98D0B9C8F836633AE2C74AA82670C933
Test 2 optical	3-layer HDLC	DIRECT_HDLC	LN	9th May 2012	1DE621B9B967E98A77EF64A66C5A61C1

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: http://www.dlms.com.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.

COSEM
Compliant

The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 10th May 2012

Paul Fuchs

Paul Fuchs
General Secretary