

## Certification No. 1131

This is to certify that the metering equipment identified as:

**Type: ST300F**

**Mgmt. LDN: SAP = 1, "4D41435354333030463333333333333333" (MACST300F33333333)**

manufactured by:

**Meter&Control**

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 2.0
- Licensed to: METER & CONTROL
- COSEM object definitions file version: Object\_defs\_v1.7\_CTT2\_090409.dat

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC on optical	DIRECT_HDLC	LN	22-nov-2009, 20:29:22	DA11EA2F5FD3E565391374E54698019E
Test 2	3-layer HDLC on RS 232	DIRECT_HDLC	LN	22-nov-2009, 20:47:50	105151862BFDCC39AE8BB7B6133E4579
Test 3	3-layer HDLC on RS 485	DIRECT_HDLC	LN	22-nov-2009, 21:13:50	45E4FE4CFA133D21D9C76D2811752AAA

Interface classes found but not tested: 71, 72, 74

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Geneva, the 24<sup>th</sup> November 2009

*Paul Fuchs*

General Secretary