



CERTIFICATE OF COMPLIANCE

Certificate N°:	2848	Issue date:	March 9th, 2023
Applicant:	Landis+Gyr AG	Issued to:	Landis+Gyr AG
	Alte Steinhauserstrasse 18		Alte Steinhauserstrasse 18
	6330-Cham		6330-Cham
	Switzerland		Switzerland

The certified product listed below is eligible to bear the DLMS UA Mark shown



PRODUCT

Model: 120mm
Type: E470 SMEST2
Firmware ID: V=24040602, V=00000000 S=0F2D2197

Mgmt LDN (SAP = 1): SAP = 1 is "4C475A31323334353637380000000000" (LGZ12345678)
Manufacturer: Landis+Gyr AG
Media Identifiers: ABSTRACT, ELECTRICITY

CONFORMANCE SPECIFICATION

COSEM IF Classes and OBIS Codes: Blue Book Ed. 14
DLMS/COSEM Protocol: Green Book Ed. 10

TEST TOOL & SPEC.

Test Specification: Yellow Book Ed. 8
Test Tool Version: DTT 4.2
Test Tool Licensee: Landis+Gyr AG
COSEM Object definition file: Object_defs_v14.2_Released_220701.dat
Communication profiles: HDLC

This Certificate of Compliance is based on an evaluation of a test report based on a single test executed on one specimen of the product, as identified by the Product data above. This Certificate is issued on the condition that the holder complies and will continue to comply with the requirement and procedures issued by DLMS UA.. The authenticity of the test report has been verified by the DLMS User Association and the equipment identified above is listed on its web site at: www.dlms.com.



CERTIFICATE OF COMPLIANCE

Certificate N°: 2848

Test File: DTT4.2_r103_V24.04.06.02 tested with DTT 4.2, release 103

* Identification *

Identification = {
Applicant = "\Landis+Gyr AG"
Manufacturer = "\Landis+Gyr AG"
FLAGid = "\LGZ"
Type = „\E470 SMETS2 120mm"
SerialNr = "\12345678"
}

* Summary *

TEST SUITE	TOTAL	PASSED	FAILED
HDLC	33	33	0
APPL	31	31	0
COSEM	1266	1266	0

Communication profile: HDLC

Logical device(s) found: SAP = 1 is "4C475A31323334353637380000000000" (LGZ12345678)

Active firmware(s): V=24040602
V=00000000 S=0F2D2197

Application context names: LONG_NAMES

Authentication mechanisms: NO_SECURITY

ACSE and xDLMS features: GET
MULTIPLE_REFERENCES
RLRQ_RLRE
SET

COSEM classes tested: 1,3,4,5,6,7(1),8,9,10,11,12(2),15(1),17,18, 20,21,22,23,30,64,70,71,111,112,113,115